



THE CITY OF SAN DIEGO

Fire-Rescue Department

Sprinkler Policies Policy FS – 0409

Inspector's Test Valve Location

Inspector's test valves should be located in the farthest most hydraulically remote area of the sprinkler system. The exact location shall be approved at plan review.

Exception: Inspector's test valves may be supplied from pipe adjacent to the riser in multi-story buildings.